

December 7, 2018
Patriot Beverages, LLC WWTP
MA0004936-1

Ms. Nam Nguyen
U.S. EPA, Water Enforcement
OES4-SMR
5 Post Office Square, Suite 100
Boston, MA 02109-3912

Dear Ms. Nguyen:


Please find attached the Monthly Operation and Maintenance Report for November 2018.

The WWTP is receiving off-site wastewater, daily, Monday through Friday from the EPIC and CPF facilities in Ayer, Ma.

Total Phosphorous discharge levels were high on the 20th and 27th sampling. The cause is being investigated. The discharge total phosphorous for 12/5/18 was less then 0.1mg/l.

If you have any questions, please contact James Drapeau at (978) 339-5905 or e-mail at jdrapeau@cpf-nehf.com.

Sincerely,



James Drapeau
Chief Wastewater Operator
CPF Inc.

Attachment: MA DEP Monthly Operations and Maintenance Report for November 2018
submitted by NetDMR
001-A Discharge Monitoring Report for November 2018 submitted by NetDMR
Off-Site Wastewater received spreadsheet for November 2018 submitted by
NetDMR

cc: MA-DEP, Central Region, Bureau of Air & Waste, Worcester
MA-DEP, Division of Watershed Mgmt., Surface Discharge Permit, Worcester